

NC/QC/YPD/2020-21/SB/W5-2-CB1

Date: 22-03-2021

1. TEST REPORT ON CEMENT CONCRETE CUBES:

Sub: Testing of Concrete Cubes (for 07days Compressive Strength).

{Project*: Improvements to Roads and Drains in Vinayakanagara, Kattigenahalli and Dwarakanagara Surrounding area in Ward No: 05.}

Ref.: Material testing/PMC/20-21,

Report Required for: Assistant Executive Engineer,
Yelahanka Project Division,
BBMP, Bangalore.

Name of the Agency/Contractor*: M/s SLP Infra Engineers Pvt Ltd (H S Yashwanth Gowda), Bangalore.

RESULTS OF COMPRESSIVE STRENGTH ON CEMENT CONCRETE

CUBE SPECIMENS

Dimensions of Specimen : 150 X 150 X 150mm

Grade of Concrete* : M₂₀

TABLE 1.1:

Sl No	Location/ Identification*	Date of Casting*	Date of Testing	Age in Days	C/S Area in mm ²	Maximum Load in K.N	Compressive Strength (N/ mm ²)	Avg. Value
1	001	15-03-21	22-03-21	07	22500	380	16.89	16.81
	002	"	"	"	"	370	16.44	
	003	"	"	"	"	385	17.11	

The result of the materials tested meets the standards and hence can be used for the work.
Sample Collected Site : Palanahalli Road, From Kattigenahalli Govt School to Lake.

Page No. 1/1,



NC/QC/YPD/2020-21/SB/W5-2-CB2

Date: 24-03-2021

I. TEST REPORT ON CEMENT CONCRETE CUBES:

Sub: Testing of Concrete Cubes (for 07days Compressive Strength).

{Project*: Improvements to Roads and Drains in Vinayakanagara, Kattigenahalli and Dwarakanagara Surrounding area in Ward No: 05.}

Ref.: Material testing/PMC/20-21,

Report Required for: Assistant Executive Engineer,
Yelahanka Project Division,
BBMP, Bangalore.

Name of the Agency/Contractor*: M/s SLP Infra Engineers Pvt Ltd (H S Yashwanth Gowda), Bangalore.

RESULTS OF COMPRESSIVE STRENGTH ON CEMENT CONCRETE

CUBE SPECIMENS

Dimensions of Specimen : 150 X 150 X 150mm
Grade of Concrete* : M₂₀

TABLE I.1:

Sl No	Location/ Identification*	Date of Casting*	Date of Testing	Age in Days	C/S Area in mm ²	Maximum Load in K.N	Compressive Strength (N/ mm ²)	Avg. Value
1	001	17-03-21	24-03-21	07	22500	360	16.00	16.07
	002	"	"	"	"	355	15.78	
	003	"	"	"	"	370	16.44	

The result of the materials tested meets the standards and hence can be used for the work.
Sample Collected Site : Palanahalli Road, From Kattigenahalli Govt School to Lake.

Page No. 1/1,



NYCN/VP4/2020-21/SB/WS-3-CB3

Date: 27-03-2021

1. TEST REPORT ON CEMENT CONCRETE CUBES:

Sub: Testing of Concrete Cubes (for 07 days Compressive Strength).

(Project: Improvements to Roads and Drains in Vinayakanagara, Kattigenahalli and
Chwarakanagara Surrounding area in Ward No: 05.)

Ref: Material testing PAK-20-21,

Report Required for: Assistant Executive Engineer,
Yelahanka Project Division,
BRMP, Bangalore.

Name of the Agency/Contractor*: M/s SLP Infra Engineers Pvt Ltd (H S Yashwanth Gowda), Bangalore.

RESULTS OF COMPRESSIVE STRENGTH ON CEMENT CONCRETE

CUBE SPECIMENS

Dimensions of Specimen : 150 X 150 X 150mm

Grade of Concrete* : M₃₀

TABLE 1.1:

Sl No	Location/ Identification*	Date of Casting*	Date of Testing	Age in Days	C/S Area in mm ²	Maximum Load in K.N	Compressive Strength (N/ mm ²)	Avg. Value
1	001	20-03-21	27-03-21	07	22500	365	16.22	16.15
	002	"	"	"	"	370	16.44	
	003	"	"	"	"	355	15.78	

The result of the materials tested meets the standards and hence can be used for the work.

Sample Collected Site : Muneshwara Layout Main Road

Page No. 1/1,





NC/QC/YPD/2020-21/SB/W5-2-CB4

Date: 31-03-2021

1. TEST REPORT ON CEMENT CONCRETE CUBES:

Sub: Testing of Concrete Cubes (for 07days Compressive Strength).

{Project*: Improvements to Roads and Drains in Vinayakanagara, Kattigenahalli and Dwarakanagara Surrounding area in Ward No: 05.}

Ref.: Material testing/PMC/20-21,

Report Required for: Assistant Executive Engineer,
Yelahanka Project Division,
BBMP, Bangalore.

Name of the Agency/Contractor*: M/s SLP Infra Engineers Pvt Ltd (H S Yashwanth Gowda), Bangalore.

RESULTS OF COMPRESSIVE STRENGTH ON CEMENT CONCRETE

CUBE SPECIMENS

Dimensions of Specimen : 150 X 150 X 150mm

Grade of Concrete* : M₂₀

TABLE 1.1:

Sl No	Location/ Identification*	Date of Casting*	Date of Testing	Age in Days	C/S Area in mm ²	Maximum Load in K.N	Compressive Strength (N/ mm ²)	Avg. Value
1	001	24-03-21	31-03-21	07	22500	370	16.44	16.67
	002	"	"	"	"	380	16.89	
	003	"	"	"	"	375	16.67	

The result of the materials tested meets the standards and hence can be used for the work.
Sample Collected Site : Vinayakanagara 2nd Main , LHS from 2nd Cross Rd.

✓

Page No. 1/1,





NC/QC/YPD/2020-21/SB/W5-2-CB5

Date: 03-04-2021

I. TEST REPORT ON CEMENT CONCRETE CUBES:

Sub: Testing of Concrete Cubes (for 07days Compressive Strength).

{Project*: Improvements to Roads and Drains in Vinayakanagara, Kattigenahalli and Dwarakanagara Surrounding area in Ward No: 05.}

Ref.: Material testing/PMC/20-21,

Report Required for: Assistant Executive Engineer,
Yelahanka Project Division,
BBMP, Bangalore.

Name of the Agency/Contractor*: M/s SLP Infra Engineers Pvt Ltd (H S Yashwanth Gowda), Bangalore.

RESULTS OF COMPRESSIVE STRENGTH ON CEMENT CONCRETE

CUBE SPECIMENS

Dimensions of Specimen : 150 X 150 X 150mm

Grade of Concrete* : M₂₀

TABLE 1.1:

Sl No	Location/ Identification*	Date of Casting*	Date of Testing	Age in Days	C/S Area in mm ²	Maximum Load in K.N	Compressive Strength (N/ mm ²)	Avg. Value
1	001	27-03-21	03-04-21	07	22500	380	16.89	16.89
	002	"	"	"	"	370	16.44	
	003	"	"	"	"	390	17.33	

The result of the materials tested meets the standards and hence can be used for the work.
Sample Collected Site : Vinayakanagara 3rd Main , LHS from Main Rd

✓

Page No. 1/1,





NC/QC/YPD/2020-21/SB/W5-2-CB6

Date: 22-07-2021

1. TEST REPORT ON CEMENT CONCRETE CUBES:

Sub: Testing of Concrete Cubes (for 07days Compressive Strength).

{Project*: Improvements to Roads and Drains in Vinayakanagara, Kattigenahalli and Dwarakanagara Surrounding area in Ward No: 05.}

Ref.: Material testing/PMC/20-21,

Report Required for: Assistant Executive Engineer,
Yelahanka Project Division,
BBMP, Bangalore.

Name of the Agency/Contractor*: M/s SLP Infra Engineers Pvt Ltd (H S Yashwanth Gowda), Bangalore.

RESULTS OF COMPRESSIVE STRENGTH ON CEMENT CONCRETE

CUBE SPECIMENS

Dimensions of Specimen : 150 X 150 X 150mm

Grade of Concrete* : M₂₀

TABLE 1.1:

Sl No	Location/ Identification*	Date of Casting*	Date of Testing	Age in Days	C/S Area in mm ²	Maximum Load in K.N	Compressive Strength (N/ mm ²)	Avg. Value
1	001	15-07-21	22-07-21	07	22500	375	16.67	16.74
	002	"	"	"	"	385	17.11	
	003	"	"	"	"	370	16.44	

The result of the materials tested meets the standards and hence can be used for the work.
Sample Collected Site : Vinayakanagara 4th Main , LHS from End.

✓

Page No. 1/1,





NC/QC/YPD/2020-21/SB/W5-2-CB7

Date: 26-07-2021

1. TEST REPORT ON CEMENT CONCRETE CUBES:

Sub: Testing of Concrete Cubes (for 07days Compressive Strength).

{Project*: Improvements to Roads and Drains in Vinayakanagara, Kattigenahalli and Dwarakanagara Surrounding area in Ward No: 05.}

Ref.: Material testing/PMC/20-21,

Report Required for: Assistant Executive Engineer,
Yelahanka Project Division,
BBMP, Bangalore.

Name of the Agency/Contractor*: M/s SLP Infra Engineers Pvt Ltd (H S Yashwanth Gowda), Bangalore.

RESULTS OF COMPRESSIVE STRENGTH ON CEMENT CONCRETE

CUBE SPECIMENS

Dimensions of Specimen : 150 X 150 X 150mm

Grade of Concrete* : M₂₀

TABLE 1.1:


Sl No	Location/ Identification*	Date of Casting*	Date of Testing	Age in Days	C/S Area in mm ²	Maximum Load in K.N	Compressive Strength (N/ mm ²)	Avg. Value
1	001	19-07-21	26-07-21	07	22500	370	16.44	16.22
	002	"	"	"	"	365	16.22	
	003	"	"	"	"	360	16.00	

The result of the materials tested meets the standards and hence can be used for the work.
Sample Collected Site : Vinayakanagara 4th Main , RHS from End

✓

Page No. 1/1,





NC/QC/YPD/2020-21/SB/W5-2-CB8

Date: 29-07-2021

1. TEST REPORT ON CEMENT CONCRETE CUBES:

Sub: Testing of Concrete Cubes (for 07days Compressive Strength).

{Project*: Improvements to Roads and Drains in Vinayakanagara, Kattigenahalli and Dwarakanagara Surrounding area in Ward No: 05.}

Ref.: Material testing/PMC/20-21,

Report Required for: Assistant Executive Engineer,
Yelahanka Project Division,
BBMP, Bangalore.

Name of the Agency/Contractor*: M/s SLP Infra Engineers Pvt Ltd (H S Yashwanth Gowda), Bangalore.

RESULTS OF COMPRESSIVE STRENGTH ON CEMENT CONCRETE

CUBE SPECIMENS

Dimensions of Specimen : 150 X 150 X 150mm
Grade of Concrete* : M₂₀

TABLE 1.1:


Sl No	Location/ Identification*	Date of Casting*	Date of Testing	Age in Days	C/S Area in mm ²	Maximum Load in K.N	Compressive Strength (N/ mm ²)	Avg. Value
1	001	22-07-21	29-07-21	07	22500	385	17.11	16.59
	002	"	"	"	"	370	16.44	
	003	"	"	"	"	365	16.22	

The result of the materials tested meets the standards and hence can be used for the work.
Sample Collected Site : Vinayakanagara, Connecting Drain 01.

(Handwritten signature)

Page No. 1/1,





NC/QC/YPD/2020-21/SB/W5-2-CB9

Date: 31-07-2021

1. TEST REPORT ON CEMENT CONCRETE CUBES:

Sub: Testing of Concrete Cubes (for 07days Compressive Strength).

{Project*: Improvements to Roads and Drains in Vinayakanagara, Kattigenahalli and Dwarakanagara Surrounding area in Ward No: 05.}

Ref.: Material testing/PMC/20-21,

Report Required for: Assistant Executive Engineer,
Yelahanka Project Division,
BBMP, Bangalore.

Name of the Agency/Contractor*: M/s SLP Infra Engineers Pvt Ltd (H S Yashwanth Gowda), Bangalore.

RESULTS OF COMPRESSIVE STRENGTH ON CEMENT CONCRETE

CUBE SPECIMENS

Dimensions of Specimen : 150 X 150 X 150mm

Grade of Concrete* : M₂₀


TABLE 1.1:

Sl No	Location/ Identification*	Date of Casting*	Date of Testing	Age in Days	C/S Area in mm ²	Maximum Load in K.N	Compressive Strength (N/ mm ²)	Avg. Value
1	001	24-07-21	31-07-21	07	22500	365	16.22	16.15
	002	"	"	"	"	370	16.44	
	003	"	"	"	"	355	15.78	

The result of the materials tested meets the standards and hence can be used for the work.
Sample Collected Site : Vinayakanagara, 5th Main Rd (SLV Appartment Road)

Page No. 1/1,





NC/QC/YPD/2020-21/SB/W5-2-CB10

Date: 04-08-2021

1. TEST REPORT ON CEMENT CONCRETE CUBES:

Sub: Testing of Concrete Cubes (for 07days Compressive Strength).

{Project*: Improvements to Roads and Drains in Vinayakanagara, Kattigenahalli and Dwarakanagara Surrounding area in Ward No: 05.}

Ref.: Material testing/PMC/20-21,

Report Required for: Assistant Executive Engineer,
Yelahanka Project Division,
BBMP, Bangalore.

Name of the Agency/Contractor*: M/s SLP Infra Engineers Pvt Ltd (H S Yashwanth Gowda), Bangalore.

RESULTS OF COMPRESSIVE STRENGTH ON CEMENT CONCRETE

CUBE SPECIMENS

Dimensions of Specimen : 150 X 150 X 150mm

Grade of Concrete* : M₂₀


TABLE I.1:

Sl No	Location/ Identification*	Date of Casting*	Date of Testing	Age in Days	C/S Area in mm ²	Maximum Load in K.N	Compressive Strength (N/ mm ²)	Avg. Value
1	001	28-07-21	04-08-21	07	22500	360	16.00	16.07
	002	"	"	"	"	355	15.78	
	003	"	"	"	"	370	16.44	

The result of the materials tested meets the standards and hence can be used for the work.
Sample Collected Site : Vinayakanagara.1st Main 1st Cross Rd , LHS From Main Rd

Page No. 1/1,





NC/QC/YPD/2020-21/SB/W5-2-CB11

Date: 07-08-2021

1. TEST REPORT ON CEMENT CONCRETE CUBES:

Sub: Testing of Concrete Cubes (for 07days Compressive Strength).

{Project*: Improvements to Roads and Drains in Vinayakanagara, Kattigenahalli and Dwarakanagara Surrounding area in Ward No: 05.}

Ref.: Material testing/PMC/20-21,

Report Required for: Assistant Executive Engineer,
Yelahanka Project Division,
BBMP, Bangalore.

Name of the Agency/Contractor*: M/s SLP Infra Engineers Pvt Ltd (H S Yashwanth Gowda), Bangalore.

RESULTS OF COMPRESSIVE STRENGTH ON CEMENT CONCRETE

CUBE SPECIMENS

Dimensions of Specimen : 150 X 150 X 150mm

Grade of Concrete* : M₂₀


TABLE 1.1:

Sl No	Location/ Identification*	Date of Casting*	Date of Testing	Age in Days	C/S Area in mm ²	Maximum Load in K.N	Compressive Strength (N/ mm ²)	Avg. Value
1	001	31-07-21	07-08-21	07	22500	375	16.67	16.74
	002	"	"	"	"	385	17.11	
	003	"	"	"	"	370	16.44	

The result of the materials tested meets the standards and hence can be used for the work.
Sample Collected Site : Vinayakanagara.1st Main 2nd Cross Rd , LHS From Main Rd

Page No. 1/1,





NC/QC/YPD/2020-21/SB/W5-2-CB12

Date: 11-08-2021

1. TEST REPORT ON CEMENT CONCRETE CUBES:

Sub: Testing of Concrete Cubes (for 07days Compressive Strength).

{Project*: Improvements to Roads and Drains in Vinayakanagara, Kattigenahalli and Dwarakanagara Surrounding area in Ward No: 05.}

Ref.: Material testing/PMC/20-21,

Report Required for: Assistant Executive Engineer,
Yelahanka Project Division,
BBMP, Bangalore.

Name of the Agency/Contractor*: M/s SLP Infra Engineers Pvt Ltd (H S Yashwanth Gowda), Bangalore.

RESULTS OF COMPRESSIVE STRENGTH ON CEMENT CONCRETE

CUBE SPECIMENS

Dimensions of Specimen : 150 X 150 X 150mm
Grade of Concrete* : M₂₀

TABLE 1.1:


Sl No	Location/ Identification*	Date of Casting*	Date of Testing	Age in Days	C/S Area in mm ²	Maximum Load in K.N	Compressive Strength (N/ mm ²)	Avg. Value
1	001	04-08-21	11-08-21	07	22500	380	16.89	16.89
	002	"	"	"	"	370	16.44	
	003	"	"	"	"	390	17.33	

The result of the materials tested meets the standards and hence can be used for the work.
Sample Collected Site : Vinayakanagara.1st Main 3rd Cross Rd , LHS From Main Rd.

✓

Page No. 1/1,





NEWZEN CONSULTANTS BANGALORE

NEW TECHNOLOGIES TO INNOVATE

NC/QC/YPD/2020-21/SB/W5-2-CB13

Date: 13-08-2021

1. TEST REPORT ON CEMENT CONCRETE CUBES:

Sub: Testing of Concrete Cubes (for 07days Compressive Strength).

{Project*: Improvements to Roads and Drains in Vinayakanagara, Kattigenahalli and Dwarakanagara Surrounding area in Ward No: 05.}

Ref.: Material testing/PMC/20-21,

Report Required for: Assistant Executive Engineer,
Yelahanka Project Division,
BBMP, Bangalore.

Name of the Agency/Contractor*: M/s SLP Infra Engineers Pvt Ltd (H S Yashwanth Gowda), Bangalore.

RESULTS OF COMPRESSIVE STRENGTH ON CEMENT CONCRETE CUBE SPECIMENS

Dimensions of Specimen : 150 X 150 X 150mm
Grade of Concrete* : M₂₀

TABLE 1.1:


Sl No	Location/ Identification*	Date of Casting*	Date of Testing	Age in Days	C/S Area in mm ²	Maximum Load in K.N	Compressive Strength (N/ mm ²)	Avg. Value
1	001	06-08-21	13-08-21	07	22500	370	16.44	16.22
	002	"	"	"	"	365	16.22	
	003	"	"	"	"	360	16.00	

The result of the materials tested meets the standards and hence can be used for the work.
Sample Collected Site : Vinayakanagara.1st Main 3rd Cross Rd , RHS From End

✓

Page No. 1/1,





NC/QC/YPD/2020-21/SB/W5-2-CB14

Date: 16-08-2021

1. TEST REPORT ON CEMENT CONCRETE CUBES:

Sub: Testing of Concrete Cubes (for 07 days Compressive Strength).

{Project*: Improvements to Roads and Drains in Vinayakanagara, Kattigenahalli and Dwarakanagara Surrounding area in Ward No: 05.}

Ref.: Material testing/PMC/20-21,

Report Required for: Assistant Executive Engineer,
Yelahanka Project Division,
BBMP, Bangalore.

Name of the Agency/Contractor*: M/s SLP Infra Engineers Pvt Ltd (H S Yashwanth Gowda), Bangalore.

RESULTS OF COMPRESSIVE STRENGTH ON CEMENT CONCRETE

CUBE SPECIMENS

Dimensions of Specimen : 150 X 150 X 150mm
Grade of Concrete* : M₂₀

TABLE 1.1:

Sl No	Location/ Identification*	Date of Casting*	Date of Testing	Age in Days	C/S Area in mm ²	Maximum Load in K.N	Compressive Strength (N/ mm ²)	Avg. Value
1	001	09-08-21	16-08-21	07	22500	365	16.22	16.30
	002	"	"	"	"	360	16.00	
	003	"	"	"	"	375	16.67	

The result of the materials tested meets the standards and hence can be used for the work.
Sample Collected Site : Vinayakanagara. 1st Main 5th Cross Rd , LHS From Cross Rd.

Page No. 1/1,



NC/QC/YPD/2020-21/SB/W5-2-CB15

Date: 19-08-2021

1. TEST REPORT ON CEMENT CONCRETE CUBES:

Sub: Testing of Concrete Cubes (for 07days Compressive Strength).
{Project*: Improvements to Roads and Drains in Vinayakanagara, Kattigenahalli and Dwarakanagara Surrounding area in Ward No: 05.}

Ref.: Material testing/PMC/20-21,
Report Required for: Assistant Executive Engineer,
Yelahanka Project Division,
BBMP, Bangalore.

Name of the Agency/Contractor*: M/s SLP Infra Engineers Pvt Ltd (H S Yashwanth Gowda), Bangalore.

RESULTS OF COMPRESSIVE STRENGTH ON CEMENT CONCRETE CUBE SPECIMENS

Dimensions of Specimen : 150 X 150 X 150mm
Grade of Concrete* : M₂₀

TABLE 1.1:

Sl No	Location/ Identification*	Date of Casting*	Date of Testing	Age in Days	C/S Area in mm ²	Maximum Load in K.N	Compressive Strength (N/ mm ²)	Avg. Value
1	001	12-08-21	09-04-21	07	22500	360	16.00	16.07
	002	"	"	"	"	355	15.78	
	003	"	"	"	"	370	16.44	

The result of the materials tested meets the standards and hence can be used for the work.
Sample Collected Site : Vinayakanagara. 1st Main 5th Cross Rd , RHS From End.

Page No. 1/1,



NC/QC/YPD/2020-21/SB/W5-2-CB1A

Date: 12-04-2021

I. TEST REPORT ON CEMENT CONCRETE CUBES:

Sub: Testing of Concrete Cubes (for 28days Compressive Strength).
{Project*: Improvements to Roads and Drains in Vinayakanagara, Kattigenahalli and Dwarakanagara Surrounding area in Ward No: 05.}
Ref.: Material testing/PMC/20-21,
Report Required for: Assistant Executive Engineer,
Yelahanka Project Division,
BBMP, Bangalore.

Name of the Agency/Contractor*: M/s SLP Infra Engineers Pvt Ltd (H S Yashwanth Gowda), Bangalore.

RESULTS OF COMPRESSIVE STRENGTH ON CEMENT CONCRETE CUBE SPECIMENS

Dimensions of Specimen : 150 X 150 X 150mm
Grade of Concrete* : M₂₀

TABLE I.1:

Sl No	Location/ Identification*	Date of Casting*	Date of Testing	Age in Days	C/S Area in mm ²	Maximum Load in K.N	Compressive Strength (N/ mm ²)	Avg. Value
1	001	15-03-21	12-04-21	28	22500	515	22.89	22.59
	002	"	"	"	"	500	22.22	
	003	"	"	"	"	510	22.67	

The result of the materials tested meets the standards and hence can be used for the work.
Sample Collected Site : Palanahalli Road, From Kattigenahalli Govt School to Lake

Page No. 1/1,





NC/QC/YPD/2020-21/SB/W5-2-CB2A

Date: 15-04-2021

1. TEST REPORT ON CEMENT CONCRETE CUBES:

Sub: Testing of Concrete Cubes (for 28days Compressive Strength).

{Project*: Improvements to Roads and Drains in Vinayakanagara, Kattigenahalli and Dwarakanagara Surrounding area in Ward No: 05.}

Ref.: Material testing/PMC/20-21,

Report Required for: Assistant Executive Engineer,
Yelahanka Project Division,
BBMP, Bangalore.

Name of the Agency/Contractor*: M/s SLP Infra Engineers Pvt Ltd (H S Yashwanth Gowda), Bangalore.

RESULTS OF COMPRESSIVE STRENGTH ON CEMENT CONCRETE
CUBE SPECIMENS

Dimensions of Specimen : 150 X 150 X 150mm
Grade of Concrete* : M₂₀

TABLE 1.1:

Sl No	Location/ Identification*	Date of Casting*	Date of Testing	Age in Days	C/S Area in mm ²	Maximum Load in K.N	Compressive Strength (N/ mm ²)	Avg. Value
1	001	17-03-21	15-04-21	29	22500	515	22.89	22.52
	002	"	"	"	"	495	22.00	
	003	"	"	"	"	510	22.67	

The result of the materials tested meets the standards and hence can be used for the work.
Sample Collected Site : Palanahalli Road, From Kattigenahalli Govt School to Lake.

Page No. 1/1,





NEWZEN CONSULTANTS BANGALORE

NEW TECHNOLOGIES TO INNOVATE

NC/QC/YPD/2020-21/SB/W5-2-CB3A

Date: 17-04-2021

1. TEST REPORT ON CEMENT CONCRETE CUBES:

Sub: Testing of Concrete Cubes (for 28days Compressive Strength).
{Project*: Improvements to Roads and Drains in Vinayakanagara, Kattigenahalli and Dwarakanagara Surrounding area in Ward No: 05.}

Ref.: Material testing/PMC/20-21,
Report Required for: Assistant Executive Engineer,
Yelahanka Project Division,
BBMP, Bangalore.

Name of the Agency/Contractor*: M/s SLP Infra Engineers Pvt Ltd (H S Yashwanth Gowda), Bangalore.

RESULTS OF COMPRESSIVE STRENGTH ON CEMENT CONCRETE

CUBE SPECIMENS

Dimensions of Specimen : 150 X 150 X 150mm
Grade of Concrete* : M₂₀

TABLE 1.1:

Sl No	Location/ Identification*	Date of Casting*	Date of Testing	Age in Days	C/S Area in mm ²	Maximum Load in K.N	Compressive Strength (N/ mm ²)	Avg. Value
1	001	20-03-21	17-04-21	28	22500	510	22.67	22.37
	002	"	"	"	"	495	22.00	
	003	"	"	"	"	505	22.44	

The result of the materials tested meets the standards and hence can be used for the work.
Sample Collected Site : Muneshwara Layout Main Road.

Page No. 1/1,



NC/QC/YPD/2020-21/SB/W5-2-CB4A

Date: 21-04-2021

1. TEST REPORT ON CEMENT CONCRETE CUBES:

Sub: Testing of Concrete Cubes (for 28days Compressive Strength).
Project*: Improvements to Roads and Drains in Vinayakanagara, Kattigenahalli and Dwarakanagara Surrounding area in Ward No: 05.
Ref.: Material testing/PMC/20-21,
Report Required for: Assistant Executive Engineer,
Yelahanka Project Division,
BBMP, Bangalore.
Name of the Agency/Contractor*: M/s SLP Infra Engineers Pvt Ltd (H S Yashwanth Gowda), Bangalore.

RESULTS OF COMPRESSIVE STRENGTH ON CEMENT CONCRETE CUBE SPECIMENS

Dimensions of Specimen : 150 X 150 X 150mm
Grade of Concrete* : M₂₀

TABLE 1.1:

Sl No	Location/ Identification*	Date of Casting*	Date of Testing	Age in Days	C/S Area in mm ²	Maximum Load in K.N	Compressive Strength (N/ mm ²)	Avg. Value
1	001	24-03-21	21-04-21	28	22500	525	23.33	22.81
	002	"	"	"	"	505	22.44	
	003	"	"	"	"	510	22.67	

The result of the materials tested meets the standards and hence can be used for the work.
Sample Collected Site : Vinayakanagara 2nd Main , LHS from 2nd Cross Rd.

[Signature]

Page No. 1/1,





NC/QC/YPD/2020-21/SB/W5-2-CB5A

Date: 24-04-2021

1. TEST REPORT ON CEMENT CONCRETE CUBES:

Sub: Testing of Concrete Cubes (for 28days Compressive Strength).

{Project*: Improvements to Roads and Drains in Vinayakanagara, Kattigenahalli and Dwarakanagara Surrounding area in Ward No: 05.}

Ref.: Material testing/PMC/20-21,

Report Required for: Assistant Executive Engineer,
Yelahanka Project Division,
BBMP, Bangalore.

Name of the Agency/Contractor*: M/s SLP Infra Engineers Pvt Ltd (H S Yashwanth Gowda), Bangalore.

RESULTS OF COMPRESSIVE STRENGTH ON CEMENT CONCRETE
CUBE SPECIMENS

Dimensions of Specimen : 150 X 150 X 150mm
Grade of Concrete* : M₂₀

TABLE 1.1:

Sl No	Location/ Identification*	Date of Casting*	Date of Testing	Age in Days	C/S Area in mm ²	Maximum Load in K.N	Compressive Strength (N/ mm ²)	Avg. Value
1	001	27-03-21	24-04-21	28	22500	495	22.00	22.22
	002	"	"	"	"	500	22.22	
	003	"	"	"	"	505	22.44	

The result of the materials tested meets the standards and hence can be used for the work.
Sample Collected Site : Vinayakanagara 3rd Main , LHS from Main Rd.

Page No. 1/1,

